

NOTICE PUBLICATION/REGULATIONS SUBMISSION

(See instructions on reverse)

STD. 400 (REV. 01-2013)

OAL FILE NUMBERS	NOTICE FILE NUMBER Z-	REGULATORY ACTION NUMBER 2017-0523-06N	EMERGENCY NUMBER
------------------	---------------------------------	--	------------------

For use by Office of Administrative Law (OAL) only

NOTICE	REGULATIONS
--------	-------------

 AGENCY WITH RULEMAKING AUTHORITY
 OFFICE OF THE STATE FIRE MARSHAL

For use by Secretary of State only

ENDORSED - FILED

In the office of the Secretary of State
0

JUL 03 2017

1:43 PM

A. PUBLICATION OF NOTICE (Complete for publication in Notice Register)

1. SUBJECT OF NOTICE	TITLE(S)	FIRST SECTION AFFECTED	2. REQUESTED PUBLICATION DATE
3. NOTICE TYPE <input type="checkbox"/> Notice re Proposed Regulatory Action <input type="checkbox"/> Other	4. AGENCY CONTACT PERSON	TELEPHONE NUMBER	FAX NUMBER (Optional)
OAL USE ONLY	ACTION ON PROPOSED NOTICE <input type="checkbox"/> Approved as Submitted <input type="checkbox"/> Approved as Modified <input type="checkbox"/> Disapproved/Withdrawn	NOTICE REGISTER NUMBER	PUBLICATION DATE

B. SUBMISSION OF REGULATIONS (Complete when submitting regulations)

1a. SUBJECT OF REGULATION(S) Hazardous Liquid Pipelines - Annual Inspections - Website address	1b. ALL PREVIOUS RELATED OAL REGULATORY ACTION NUMBER(S)
---	--

2. SPECIFY CALIFORNIA CODE OF REGULATIONS TITLE(S) AND SECTION(S) (Including title 26, if toxics related)

SECTION(S) AFFECTED (List all section number(s) individually. Attach additional sheet if needed.)	ADOPT
	AMEND
	REPEAL
TITLE(S) 19	

3. TYPE OF FILING

<input type="checkbox"/> Regular Rulemaking (Gov. Code §11346)	<input type="checkbox"/> Certificate of Compliance: The agency officer named below certifies that this agency complied with the provisions of Gov. Code §§11346.2-11347.3 either before the emergency regulation was adopted or within the time period required by statute.	<input type="checkbox"/> Emergency Readopt (Gov. Code, §11346.1(h))	<input checked="" type="checkbox"/> Changes Without Regulatory Effect (Cal. Code Regs., title 1, §100)
<input type="checkbox"/> Resubmittal of disapproved or withdrawn nonemergency filing (Gov. Code §§11349.3, 11349.4)		<input type="checkbox"/> File & Print	<input type="checkbox"/> Print Only
<input type="checkbox"/> Emergency (Gov. Code, §11346.1(b))	<input type="checkbox"/> Resubmittal of disapproved or withdrawn emergency filing (Gov. Code, §11346.1)	<input type="checkbox"/> Other (Specify)	

4. ALL BEGINNING AND ENDING DATES OF AVAILABILITY OF MODIFIED REGULATIONS AND/OR MATERIAL ADDED TO THE RULEMAKING FILE (Cal. Code Regs. title 1, §44 and Gov. Code §11347.1)
N/A

5. EFFECTIVE DATE OF CHANGES (Gov. Code, §§11343.4, 11346.1(d); Cal. Code Regs., title 1, §100)


<input type="checkbox"/> Effective January 1, April 1, July 1, or October 1 (Gov. Code §11343.4(a))	<input type="checkbox"/> Effective on filing with Secretary of State	<input checked="" type="checkbox"/> \$100 Changes Without Regulatory Effect	<input type="checkbox"/> Effective other (Specify)
---	--	---	--

6. CHECK IF THESE REGULATIONS REQUIRE NOTICE TO, OR REVIEW, CONSULTATION, APPROVAL OR CONCURRENCE BY, ANOTHER AGENCY OR ENTITY

<input type="checkbox"/> Department of Finance (Form STD. 399) (SAM §6660)	<input type="checkbox"/> Fair Political Practices Commission	<input type="checkbox"/> State Fire Marshal
<input type="checkbox"/> Other (Specify)		

7. CONTACT PERSON Diane Arend	TELEPHONE NUMBER (916) 324-9592	FAX NUMBER (Optional) (916) 445-8458	E-MAIL ADDRESS (Optional) diane.arend@fire.ca.gov
----------------------------------	------------------------------------	---	--

8. I certify that the attached copy of the regulation(s) is a true and correct copy of the regulation(s) identified on this form, that the information specified on this form is true and correct, and that I am the head of the agency taking this action, or a designee of the head of the agency, and am authorized to make this certification.

SIGNATURE OF AGENCY HEAD OR DESIGNEE 	DATE 5/15/17
TYPED NAME AND TITLE OF SIGNATORY Dennis Mathisen, State Fire Marshal	

For use by Office of Administrative Law (OAL) only

ENDORSED APPROVED

JUL 06 2017

Office of Administrative Law

Title 19
Division 1
Chapter 14
Article 2

Section 2021. Form PSD-101 Requirements

(a) ***

2. Instructions for Form PSD-101 (dated ~~April~~May 1, 2017).

Note: Authority cited: Section 51015.1, Government Code. Reference: Section 51015.1, Government Code.

TEXT OF REGULATIONS
California Code of Regulations
Title 19. Public Safety
Division 1. State Fire Marshal
Chapter 14. Hazardous Liquid Pipeline Safety

Article 1. Scope

§ 2000.

Title 49 of the Code of Federal Regulations, Part 195 is hereby adopted by reference as it relates to hazardous liquid pipelines.

Note: Authority cited: Sections 51010.6 and 51011, Government Code. Reference: Sections 51010.6 and 51011, Government Code.

Article 2. Annual Inspection of Intrastate Hazardous Liquid Pipelines and Operators of Intrastate Hazardous Liquid Pipelines

§ 2020. Annual Inspection.

To implement Section 51015.1(a) of the Government Code, the Office of the State Fire Marshal shall conduct an annual inspection of every intrastate hazardous liquid pipeline and every operator of an intrastate hazardous liquid pipeline. The inspection shall include the following:

- (a) Evaluation of the risks to each intrastate hazardous liquid pipeline based upon the operation history, integrity testing results, preventative and mitigative measures, construction activities, leak history, and compliance history.
- (b) An annual inspection of each operator of an intrastate hazardous liquid pipeline in accordance with Office of the State Fire Marshal Pipeline Safety Annual Inspection Procedure (dated April 1, 2017) which is hereby incorporated by reference.
- (c) An annual inspection of each intrastate hazardous liquid pipeline in accordance with Office of the State Fire Marshal Pipeline Safety Annual Inspection Procedure (dated April 1, 2017) which is hereby incorporated by reference.

Note: Authority cited: Section 51015.1, Government Code. Reference: Section 51015.1, Government Code.

§ 2021. Form PSD-101 Requirements

(a) The following forms, in the format developed by the Office of the State Fire Marshal, which are hereby incorporated by reference, shall be used for hazardous liquid pipeline annual inspections:

1. California Intrastate Pipeline Operator Annual Report, PSD-101 (dated July 1, 2016).
2. Instructions for Form PSD-101 (dated ~~April 1, 2017~~ May 1, 2017).

(b) Each operator of an intrastate hazardous liquid pipeline shall complete and submit to the Office of the State Fire Marshal Form PSD-101 for each intrastate hazardous liquid pipeline no later than July 1st annually.

(1) The Office of the State Fire Marshal shall approve requests for a 30-day extension, if the operator has shown good cause in a written request submitted to the Pipeline Safety Division Office no later than June 1st.

(c) Each operator of an intrastate hazardous liquid pipeline shall have available for review by the Office of the State Fire Marshal documentation to substantiate the information provided in the Form PSD-101.

Note: Authority cited: Section 51015.1, Government Code. Reference: Section 51015.1, Government Code.

§ 2030. Violations

Failure to comply with any of the above provisions of this chapter shall be subject to enforcement action under Section 51018.6 of the Government Code.

Note: Authority cited: Section 51015.1, Government Code. Reference: Sections 51015.1 and 51018.6



CAL FIRE - OFFICE OF THE STATE FIRE MARSHAL
Instructions for Form PSD-101 (~~April~~May 1, 2017)
CALIFORNIA INTRASTATE PIPELINE OPERATOR ANNUAL REPORT

GENERAL INSTRUCTIONS

All section references are to Title 49 of the Code of Federal Regulations (49 CFR) and the California Elder Pipeline Safety Act. The Office of the State Fire Marshal (OSFM) Form PSD-101 is required per Government Code §51015.1(a) and Title 19, California Code of Regulations, Chapter 14, Article 2.

By May 1st of each year, the OSFM will provide each California intrastate pipeline operator a Form PSD-101. The Form PSD-101 will be divided by OSFM Inspection Unit and will include each OSFM jurisdictional pipeline that was included in the OSFM Annual Questionnaire for the previous year. Please use a separate page to identify additional pipelines.

Each pipeline operator is required to annually complete and submit a Form PSD-101 to OSFM by July 1st that represents the operator's pipeline assets as of December 31st of the previous calendar year. The completed Form PSD-101 will identify scheduled projects for the next calendar year and will contain inspection data and validated inspection results from the previous calendar year for each jurisdictional pipeline. Operators must maintain documentation to substantiate the information provided in their Form PSD-101.

If an operator is unable to submit the Form PSD-101 by July 1st, the Office of the State Fire Marshal shall approve requests for a 30-day extension, if the operator has shown good cause in a written request submitted to the Pipeline Safety Division Office no later than June 1st.

SUBMISSION METHOD

The OSFM will send an electronic version of each Form PSD-101 to the operator staff that has been designated to complete the annual OSFM Pipeline Questionnaire. The Form PSD-101 will be populated with the company information (Name, ID, Inspection Units, and CSFM Line ID) that is currently on file with the OSFM. If any information included in the form is incorrect, please enter the correct information using **RED** text to identify the change.

Each completed Form PSD-101 must be emailed to the Pipeline Safety Division Staff Service Analyst at FirstName.LastName@fire.ca.gov. If the operator is unable to email the Form PSD-101, the operator will need to print a copy and mail the form to the Pipeline Safety Division Lakewood Office at:

CAL FIRE – Office of the State Fire Marshal
Pipeline Safety Division
3950 Paramount Blvd., Suite 210
Lakewood, CA 90712

NOTE: Form PSD-101 must be post marked no later than July 1st.

COMPANY INQUIRY – The following questions refer to the operator’s overall intrastate hazardous liquid pipeline systems.

COMPANY OPERATIONS

Annual Report Code

CO.01 Have there been any asset acquisitions or divestitures in the last calendar year?

Select “Yes” from the drop-down menu, if the operator had an acquisition or divestiture of an OSFM jurisdictional hazardous liquid pipeline or facility during the previous calendar year.

CO.02 Are there any new construction projects scheduled for the next calendar year?

When answering question CO.02, operators must consider all new construction projects that are scheduled for the next calendar year. New construction projects include the design, construction, or testing of new pipelines, facilities, or breakout tanks that will be under the jurisdiction of the OSFM. Do not include replacement or relocation projects on existing pipelines. Replacement or relocation projects will be captured in the Annual Report Code PR.01 for each pipeline.

Select “Yes” from the drop-down menu, if the operator has a new construction project scheduled for the next calendar year.

CO.03 Are there any spill drills planned or scheduled for the next calendar year?

Select “Yes” from the drop-down menu, if the operator has planned or scheduled for the next calendar year a spill drill for any pipeline in this inspection unit.

PIPELINE INQUIRY – The following questions refer to each of the operator’s intrastate hazardous liquid pipelines.

PIPELINE OPERATIONS:

PIPELINE SPECIFICATIONS

PS.01 Total length of pipeline (miles)

Enter the total length of each pipeline measured in miles to 2 decimal places.

PS.02 Could the pipeline affect High Consequence Areas (HCA’s)?

Select “Yes” from the drop-down menu, if any part of the pipeline could affect a High Consequence Area (HCA) as defined in Title 49 CFR, Part 195.450.

PS.03 If yes, what are the total miles that could affect HCA's?

Enter the total miles of each pipeline that could affect a HCA.

PS.04 What is the maximum temperature of the product being transported?

Enter the maximum temperature in Fahrenheit of the product transported in each pipeline.

PS.05 What is the highest Maximum Operating Pressure (MOP) on the pipeline?

Enter the highest MOP for the entire pipeline.

PS.06 What is the limiting factor for the MOP?

Enter the limiting factor that was used to determine the MOP of each pipeline. Use the drop-down menu to select from the following: Internal Design Pressure of the Pipe; Design Pressure of any other Component; 80% of the Test Pressure; 80% of the Factory Test Pressure of any component as defined in Title 49 CFR, Part 195.406.

What commodities are transported or contained in this pipeline?

Enter the commodity transported in each pipeline. Use the drop-down menu to select from the following: Crude Oil; Refined Products (non-HVL); Jet Fuel (only); Natural Gasoline; Natural Gas Liquids; Carbon Dioxide; Anhydrous Ammonia; Highly Volatile Liquid; Fuel Grade Ethanol; Biodiesel Blend; Water; Nitrogen; Drilling Mud; Natural Gas. If multiple commodities are transported or are contained in

the pipeline, use PS.07 through PS.10 to select all commodities that apply as defined in Title 49 CFR, Part 195.2.

PS.07 Commodity #1

PS.08 Commodity #2

PS.09 Commodity #3

PS.10 Commodity #4

PS.11 Are there any Breakout Tanks associated with this pipeline?

Select "Yes" from the drop-down menu, if there are any Breakout Tanks that meet the definition in Title 49 CFR, Part 195.2 and are associated to this pipeline.

MILES OF PIPE BY TYPE – All miles of pipe shall be reported to 2 decimal places. Do not use feet to report miles of pipe.

MP.01 Buried Pipe

Enter the total miles of buried pipe for each pipeline.

MP.02 Aboveground Pipe

Enter the total miles of aboveground pipe for each pipeline.

MP.03 Coated Pipe

Enter the total miles of coated pipe for each pipeline.

MP.04 Bare Pipe

Enter the total miles of bare pipe for each pipeline.

MP.05 Insulated Pipe

Enter the total miles of insulated pipe for each pipeline.

MP.06 Pre-1970 Electric Resistance Welded (ERW) Pipe

Enter the total miles of pre-1970 ERW pipe for each pipeline.

MP.07 Operating at greater than 20% Specified Minimum Yield Strength (SMYS)

Enter the total miles of pipe operating at greater than 20% SMYS for each pipeline.

MP.08 Operating at less than or equal to 20% SMYS

Enter the total miles of pipe operating at less than or equal to 20% SMYS for each pipeline.

MP.09 Operating at an unknown stress level

Enter the total miles of pipe operating at an unknown stress level for each pipeline.

INTEGRITY TESTING:

ASSESSMENT INFORMATION

IM.01 What is the continual Integrity Assessment method for the prior calendar year?

Enter type of integrity assessment that is performed on each pipeline according to the operators Integrity Management Plan. If the pipeline is not covered under Title 49 CFR, Part 195.452, use the required testing interval from the California Government Code, Section 51013.5.

Use the drop-down menu to select from the following: In-Line Inspection; Hydrostatic Pressure Test; Other.

IM.02 When is the next Integrity Inspection due?

Enter the date when the next integrity assessment is due according to the operators Integrity Management Plan. If the pipeline is not covered under Title 49, Part CFR 195.452, use the required testing interval from the California Government Code, Section 51013.5.

IN-LINE INSPECTIONS – If the continual Integrity Assessment method selected for question IM.01 was Hydrostatic Pressure Test or Other, skip questions IL.01 through IL.23.

IL.01 When was the most recent In-Line Inspection (ILI) completed?

Enter the date of the most recent ILI. If multiple ILI tool runs were conducted to complete the inspection of the entire pipeline, use the following format:

04/01/2009 (10"), 05/01/2010 (12"), 02/01/2009 (16")

IL.02 Has the final ILI evaluation report been received from the most recent ILI?

If No, answer the remainder of the questions in this section based on this previous ILI and its associated final ILI evaluation report.

IL.03 When was the previous ILI completed?

Enter the date the previous ILI was completed. If multiple ILI tool runs were conducted to complete the inspection of the entire pipeline, use the following format:

04/01/2009 (10"), 05/01/2010 (12"), 02/01/2009 (16")

Type(s) of ILI tool(s) used:

If multiple ILI tools were used in the above referenced ILI, use the IL.04-IL.07 to select all that apply.

- IL.04 Tool Type #1
- IL.05 Tool Type #2
- IL.06 Tool Type #3
- IL.07 Tool Type #4

Enter type of ILI tool used in the last inspection. Use the drop-down menu to select from the following: Corrosion or Metal Loss Tool; Dent or Deformation Tools; Crack or Long Seam Defect Detection Tool; Other Internal Inspection Tool. If multiple ILI tool runs were conducted using different tool types to complete the inspection of the entire pipeline, please use a separate page to identify the different ILI tool types for each ILI tool run. [Title 49 CFR, Part 195.452(j)(5)]

- IL.08 Were there any external corrosion anomalies identified from the last validated ILI evaluation based on the operator's repair criteria, both within a segment that could affect a HCA and outside of a segment that could affect a High Consequence Area (HCA)?

Select "Yes" from the drop-down menu, if there were any external corrosion anomalies identified based on the operator's repair criteria even if those criteria are different from the repair criteria in Integrity Management (IM) regulations pursuant to Title 49 CFR, Part 195.452 applicable to anomalies in pipeline segments that could affect HCA per Title 49 CFR, Part 195.452 (i.e., require repair of damage more or less significant). The operator's criteria for anomalies in segments that could affect a HCA must be at least as conservative as those required by the IM regulations.

- IL.09 Were there any internal corrosion anomalies identified from the last validated ILI evaluation based on the operator's repair criteria, both within a segment that could affect a HCA and outside of a segment that could affect a HCA?

Select "Yes" from the drop-down menu, if there were any internal corrosion anomalies identified based on the operator's repair criteria even if those criteria are different from the repair criteria in IM regulations applicable to anomalies in pipeline segments that could affect HCA per Title 49 CFR, Part 195.452 (i.e., require repair of damage more or less significant). The operator's criteria for anomalies in segments that could affect a HCA must be at least as conservative as those required by the IM regulations.

- IL.10 Were there any dent or gouge anomalies identified from the last validated ILI evaluation based on the operator's repair criteria, both within a segment that could affect a HCA and outside of a segment that could affect a HCA?

Select "Yes" from the drop-down menu, if there were any dents or gouges identified based on the operator's repair criteria even if those criteria are different from than the repair criteria in IM regulations applicable to anomalies in pipeline segments that could affect HCA per Title 49 CFR, Part 195.452 (i.e., require repair of damage more or less significant). The operator's criteria for anomalies in segments that could affect a HCA must be at least as conservative as those required by the IM regulations.

- IL.11 Were there any cracks or crack-like anomalies identified from the last validated ILI evaluation based on the operator's repair criteria, both within a segment that could affect a HCA and outside of a segment that could affect a HCA?

Select "Yes" from the drop-down menu, if there were any cracks or crack-like anomalies identified based on the operator's repair criteria even if those criteria are different from than the repair criteria in IM regulations applicable to anomalies in pipeline segments that could affect HCA per 49 CFR 195.452 (i.e., require repair of damage more or less significant). The operator's criteria for anomalies in segments that could affect a HCA must be at least as conservative as those required by the IM regulations.

- IL.12 Were there any manufacturer defect anomalies identified from the last validated ILI evaluation based on the operator's repair criteria, both within a segment that could affect an HCA and outside of a segment that could affect a HCA?

Select "Yes" from the drop-down menu, if there were any manufacturer defect anomalies identified based on the operator's repair criteria even if those criteria are different from than the repair criteria in IM regulations applicable to anomalies in pipeline segments that could affect HCA per 49 CFR 195.452 (i.e., require repair of damage more or less significant). The operator's criteria for anomalies in segments that could affect a HCA must be at least as conservative as those required by the IM regulations.

- IL.13 Are the same repair criteria utilized in HCA's and non-HCA's?

Select "Yes" from the drop-down menu, if the operator uses the same repair or response criteria for anomalies identified in HCA's and non-HCA's. Select "No" from the drop-down menu, if the operator uses different repair/response criteria for anomalies identified in HCA's and non-HCA's.

For the following questions, include all actions taken during the previous calendar year that resulted from information obtained during an ILI inspection. This should also include actions taken as a result of ILI inspections conducted during prior years and for which all required actions were not completed during the year of the inspection.

- IL.14 The total number of anomalies excavated in the previous calendar year because they met the operator's criteria for excavation.

Enter the total number of anomalies excavated in the previous calendar year based on the operator's criteria for excavation. Enter a value for each pipeline, using zero (0) as appropriate.

- IL.15 Total number of anomalies repaired in the previous calendar year that were identified by ILI based on the operator's repair criteria, both within a segment that could affect an HCA and outside of a segment that could affect a HCA.

Enter the total number of anomalies repaired based on the operator's repair criteria even if those criteria are different from than the repair criteria in IM regulations applicable to anomalies in pipeline segments that could affect a HCA per 49 CFR 195.452 (i.e., require repair of damage more or less significant). The operator's criteria for anomalies in segments that could affect a HCA must be at least as conservative as those required by the IM regulations.

Include in the total only those anomalies actually repaired, not those for which other mitigated actions, such as recoating, were taken or those anomalies eliminated by pipe replacement.

Enter a value for each pipeline, using zero (0) as appropriate.

- IL.16 Was a pressure reduction taken or the pipeline shut down in response to remediating a condition identified from an integrity assessment?

Select "Yes" from the drop-down menu, if a pressure reduction was taken or the pipeline was shut down in response to remediating a condition identified from an integrity assessment. Select "No" from the drop-down menu, if there was no need to reduce the pressure or shutdown the pipeline in response to remediating a condition identified from an integrity assessment.

Total number of conditions repaired WITHIN A SEGMENT THAT COULD AFFECT AN HCA meeting the definition of:

- IL.17 1. "Immediate repair conditions" [49 CFR 195.452(h)(4)(i)]

Report only the anomalies in pipeline segments that could affect an HCA that were repaired because they met the "immediate repair conditions" criteria in the IM regulations 49 CFR 195.452(h)(4)(i). Enter a value for each pipeline, using zero (0) as appropriate.

- IL.18 2. Other repair conditions required by 49 CFR 195.452

Report only the anomalies in pipeline segments that could affect an HCA that were repaired because they met the a repair criteria in the IM regulations 49 CFR 195.452(h)(4) other than

an "immediate repair conditions". Enter a value for each pipeline, using zero (0) as appropriate.

IL.19 Is the operator waiting for permits to remediate anomalies?

Select "Yes" from the drop-down menu, if the operator is waiting for permits to remediate an anomaly identified on the pipeline during the last ILI evaluation.

If Yes:

IL.20 1. How many days has the permitting process been in progress?

Enter the number of days since the operator has submitted the permit to remediate the anomaly. If there are multiple anomalies on this pipeline waiting on permits to be remediated, than enter the information for the anomaly that has been in the permit process the longest.

IL.21 2. Has the pressure reduction exceeded 365 days?

Select "Yes" from the drop-down menu, if a pressure reduction taken on this pipeline in response to remediating a condition identified from an integrity assessment exceeded 365 days.

If Yes:

IL.22 1. Has the operator notified PHMSA or OSFM?

Select "Yes" from the drop-down menu, if the operator has notified PHMSA and OSFM of a pressure reduction taken on this pipeline in response to remediating a condition identified from an integrity assessment that exceeded 365 days.

IL.23 COMMENTS:

Use this text box to further explain or clarify answers given in the IN-LINE INSPECTIONS Section.

HYDROSTATIC PRESSURE TESTING

HP.01 Date of last pressure test (include CSFM Test ID)

Enter the date of the last pressure test completed on the entire pipeline and enter the CSFM Test ID assigned to this pressure test. If multiple hydrostatic pressure tests were conducted to complete the inspection of the entire pipeline, use the following format:

04/01/2009 (CSFM Test ID 00-000), 05/01/2010 (CSFM Test ID 00-000), 02/01/2009 (CSFM Test ID 00-000)

HP.02 Was a spike test completed?

Select "Yes" from the drop-down menu, if a spike test was completed during the last pressure test completed on the entire pipeline.

HP.03 Were there any pressure test failures (ruptures and leaks) during the last pressure test?

Select "Yes" from the drop-down menu, if a pressure test failure occurred on the last pressure test completed on the entire pipeline. Small leaks on pipe valves or flange gaskets are not considered a pressure test failure.

PREVENTATIVE and MITIGATIVE MEASURES:

CONTROL ROOM MANAGEMENT/SCADA

CR.01 Is a Supervisory Control and Data Acquisition (SCADA) system used to monitor or control all or part of this pipeline?

Select "Yes" from the drop-down menu, if a Supervisory Control and Data Acquisition (SCADA) system, as defined by 49 CFR 195.2, is used to monitor or control all or part of the pipeline.

CR.02 Is there a control room, as defined in 49 CFR 195.2, associated with this pipeline?

If Yes,

CR.03 Where is the primary control center located?

Enter the City and State of the primary control center.

LEAK DETECTION SYSTEM

LD.01 Is a Computational Pipeline Monitoring (CPM) leak detection system used on this pipeline?

Select "Yes" from the drop-down menu, if a Computational Pipeline Monitoring (CPM) leak detection system, as defined by 49 CFR 195.2, is used on this system.

LD.02 If a CPM leak detection system is not used, describe how leaks are detected on the pipeline?

Use this text box to explain how leaks and ruptures are detected on this pipeline.

CORROSION CONTROL

CC.01 What type of cathodic protection is used on this pipeline?

Use the drop-down menu to select from the following: Galvanic Anode, Impressed Current; Both Galvanic Anode and Impressed Current; None.

CC.02 When was the last close-interval survey performed on this line?

Enter the date of the last close-interval survey (CIS) performed on any portion of the pipeline. Close interval surveys are a detailed potential survey conducted on a pipeline to assess the effectiveness of the cathodic protection system. Enter "Never", if a CIS has not been conducted on this pipeline.

CC.03 Has the corrosive effect of the hazardous liquid on the pipeline been investigated?

Select "Yes" from the drop-down menu, if the operator has investigated the corrosive effect of the hazardous liquid transported in the pipeline.

CC.04 Are corrosion inhibitors used to mitigate internal corrosion?

Select "Yes" from the drop-down menu, if corrosion inhibitors are used to mitigate internal corrosion of the pipeline.

NATURAL FORCE RISKS

NF.01 Does this pipeline cross known active faults?

Select "Yes" from the drop-down menu, if the pipeline crosses a known active fault. The OSFM recommends the operator use the USGS Quaternary Fault and Fold Database to verify if the pipeline crosses an active fault. This is an online database found at <http://Qfaults.cr.usgs.gov/> <https://earthquake.usgs.gov/hazards/qfaults/> that contains information on faults and associated folds that are believed to be sources of earthquakes greater than magnitude 6 (M>6). The database is limited to structures with documented activity during the Quaternary

(past 1.6 million years) because this period of geologic time is most relevant for studies of active earthquake faults

PROJECTS

PROJECTS SCHEDULED (Next Calendar Year)

PR.01 Relocation/Replacement/Reconditioned Projects

Select "Yes" from the drop-down menu, if any of the following projects are scheduled for the next calendar year:

- 1) A relocation or replacement of any portion of the pipeline that is greater than 1,000 feet in total length.
- 2) A project to recondition or recoat any portion of the pipeline that is greater than 1,000 feet in total length.

PR.02 Cathodic Protection (CP) Projects

Select "Yes" from the drop-down menu, if a cathodic protection project is schedule for the next calendar year that is needed to comply with 49 CFR 195.571 and is anticipated to cost more than \$50,000.